



October 22, 2009

Jefferson Middle School
Jamestown, New York

Attn: Ray Fashano

Fourth complete evaluation billing period for Power Shaver Energy Saving System

Billing period: 8-28-09 to 9-28-09

Reductions compared to same period 2008

kWh:	-42,720	=	-26.3%
kW:	+15	=	+2.8%
rkVarh:	-115	=	-42.5%
Cost:	-\$ 1,721.04	=	-16.4%
Cost per kWh:	0.06374	=	+ 0.00552 compared to 2008
Average temperature:	60.5 degrees	=	- .56 degrees compared to 2008

Jefferson Middle School is continuing to yield reductions in use and cost compared to last September that is a more average representation of their use even with a slight increase in cost. The weather was Cooler on average over 2008.

Thank you,

John Knapp

Power Shaver