


Trump Hotel - Small Service - Real Power

4/2/2014 2:27:22 PM - 4/2/2014 3:21:50 PM




Real Power Total (297030.59 W, min:283874.34 W; max:301210.94 W; avg:292855.95 W)

Trump Hotel - Small Service - Apparent Power

4/2/2014 2:27:22 PM - 4/2/2014 3:21:50 PM


USES turned On at 3:07:21



Apparent Power Total (307548.47 VA, min:284437.50 VA; max:321516.09 VA; avg:300699.80 VA)

Trump Hotel - Small Service - Reactive Power

4/2/2014 2:27:22 PM - 4/2/2014 3:21:50 PM




USES turned On at 3:07:21

Reactive Power Total (13970.26 VAR, min:16966.17 VAR, max:115537.11 VAR, avg:56890.72 VAR)

Trump Hotel - Small Service - Power Factor


4/2/2014 2:27:22 PM - 4/2/2014 3:21:50 PM



True Power Factor Total (0.961, min:1.001; max:0.931; avg:0.971)

Trump Hotel - Small Service - RMS Current

4/2/2014 2:27:22 PM - 4/2/2014 3:21:50 PM




USES turned On at 3:07:21

RMS Current Ø1 (398.07 A, min:373.06 A; max:421.98 A; avg:394.58 A) RMS Current Ø2 (356.22 A, min:325.84 A; max:382.10 A; avg:348.50 A)
 RMS Current Ø3 (357.42 A, min:333.22 A; max:374.55 A; avg:352.36 A)

Trump Hotel - Small Service - RMS Voltage

4/2/2014 2:27:22 PM - 4/2/2014 3:21:50 PM



RMS Voltage Ø12 (475.16 V, min:473.66 V; max:477.68 V; avg:475.54 V) RMS Voltage Ø32 (475.31 V, min:473.74 V; max:477.89 V; avg:475.70 V)
 RMS Voltage Ø31 (476.49 V, min:474.86 V; max:478.84 V; avg:476.74 V)