



**Cutler-Hammer**

**EATON**

## **ENGINEERING SERVICES & SYSTEMS**

**3 Chelsea Parkway  
Suite 304  
Boothwyn, Pa 19061**

**G.O. # ELY000502  
TQS1456.001**

**Date Report Completed: 5/11/99**

## **POWER MEASUREMENTS**

**FOR**

**NORTHROP GRUMMAN CORP.  
RADAR TEST FACILITY  
CHILLER 2A**

**SYKESVILLE, MD**

---

**C-H ESS  
CUTLER-HAMMER ENGINEERING SERVICES AND SYSTEMS DIVISION  
-D84-**

**ENGINEERING SERVICES & SYSTEMS**

**3 Chelsea Parkway  
Suite 304  
Boothwyn, Pa 19061**

<b>General Order #</b>	<b>ELY000502</b>
<b>TQS #</b>	<b>1456.001</b>
<b>Preliminary Report Completed:</b>	<b>4/23/99</b>
<b>Final Report Completed:</b>	<b>5/11/99</b>
<b>Report Completed By:</b>	<b>Alton W. Baum, P.E.</b>

**POWER MEASUREMENTS**

**FOR**

**NORTHROP GRUMMAN CORP.  
RADAR TEST FACILITY  
CHILLER 2A**

**SYKESVILLE, MD**

**Cutler-Hammer**

## Table of Contents

<u>SECTION</u>	<u>PAGE</u>
1      OVERVIEW	1
2      PERSONNEL	1
3      SYSTEM DESCRIPTION	1
4      MOTOR/COMPRESSOR DATA	2
5      POWER ANALYZER DESCRIPTION	2
6      TEST PROCEDURE	2
7      TEST RESULTS	3
8      CONCLUSION	4
PP1 SPECIFICATIONS	5
DATA SHEETS	A1-A4, B1-B4, C1-C4, D1-D5, E1-E5

**Cutler-Hammer**

*Northrop Grumman (TQS1456.001)*



## 1 OVERVIEW

The Northrop Grumman Radar Test Laboratory in Sykesville, Maryland recently installed an active line power conditioner, called the USES unit. The USES is connected to a 150 horsepower compressor motor identified by the facility as "Chiller 2A". The motor of Chiller 2A is a low voltage induction motor started across-the-line. The USES is a three phase passive line conditioner that functions to: a) reduce demand from the power system, b) provide transient surge protection, c) reduce harmonics, and d) improve power factor. The USES unit under test is model # CMES 3D 480.

In April 1999, Northrop Grumman Corp. in conjunction with the USES distributor, Pure Power Systems, Inc. contracted Cutler-Hammer Engineering Services and Systems (C-HESS) to measure and record power and harmonic data on Chiller 2A. This report documents the measurement techniques, test equipment specifications, system details, and test results. Data are summarized in section 7 of this report, with complete details of the testing shown in subsequent data section. These power measurements of the USES Unit are intended to be the first of a series of tests which will include harmonics and transient attenuation.

## 2 PERSONNEL

Mohan Ray, PE	Sr. Facilities Design Engineer	Northrop Grumman
Robert Emmet, PhD	Product Sales Representative	Pure Power Systems
Jim Kerr	Plant Electrician	Northrop Grumman
Doug Shade	Service Technician	McQuay, Inc.
Dennis Lofink	Sr. Sales Engineer	C-HESS
Alton Baum, PE	Power Systems Engineer	C-HESS

## 3 SYSTEM DESCRIPTION

Chiller 2A is rated 150hp at 480V, with full load current (running load amperes, RLA) equal to 180A. The USES Unit is connected in parallel to the 3-phase motor feed on the line-side of the motor starter contactor. The USES Unit has its own 30A molded case breaker for switched isolation.

The cut-away oneline diagram shows the electrical configuration of Chiller 2A and its feed from Substation #4, 225A molded case breaker. Also shown in this layout are the connection points of both the USES and the power monitoring.

**Cutler-Hammer**

#### 4 MOTOR/COMPRESSOR DATA

Mfgr.: McQuay International, Inc.  
460V, 3-phase, 60Hz., 182 FLA (RLA), 409 LRA (wye), 1,228 LRA (delta)  
0.882 rated power factor (FLA)

Unit Shop Order # 506180010  
Motor Style# 704826CG06  
Compressor Model# CE063JAP 18ROX  
Compressor Style# 701620AG70  
Compressor Serial# 5WFOOT5602

#### 5 POWER ANALYZER DESCRIPTION

The Power Platform PP1, manufactured by Dranetz-BMI, Inc., Edison, NJ was used as the primary recording device for this project. The PP1, when used with the Task8000 taskcard allows the meter to measure and record power parameters for both single-phase and three-phase systems. These parameters include: voltage, current, real power, reactive power, apparent power, power factor, and voltage and current harmonics.

In conjunction with the PP1, two other power meters were used as comparable data measurements. These were the ACE2000, manufactured by CPM, Inc., Toronto, Ont., and the Fluke 41 B. Data from these units are not included in this report, however, verification of recorded parameters of these units compared favorably with the Dranetz PP1 data.

The PP1 was last calibrated on 7/21/98, and is due for updated calibration on 7/21/99. Technical specifications of the unit follow section 8 of this report.

#### 6 TEST PROCEDURE

The overall purpose of this testing was to measure and record power parameters of Chiller 2A under various load conditions both with and without the USES unit connected to the feeder. The power analyzer (PP1) was connected to the load side of the 225A feeder breaker. Power measurements were recorded by manual initiation, as opposed to threshold triggering, during specific loading conditions and USES operation. For instance, with Chiller 2A running at 100% RLA and the USES unit breaker closed, measurements were initiated. At this same loading, the USES breaker was opened, and a new set of measurements was recorded.

**Cutler-Hammer**

Load was changed on the chiller by varying the programmable chilled water temperature point. This adjustment allowed for a load range from 100% to 50% RLA. Consequently, power measurements were recorded under 100%, 90%, 75% and 50% load conditions for the USES connected and disconnected to the feeder.

## 7 TEST RESULTS

7.1 Printed results from the PP1 recorded measurements are provided through pages A-1 to E-5. These data sheets contain power measurements, voltage and current phasor diagrams and sinusoidal waveforms, and harmonic data. For ease of comparison, these measurements are summarized in the Data Summary Table below for each load condition and with the USES Unit switched on and off.

**DATA SUMMARY TABLE**

	100% RLA		90% RLA		75% RLA		50% RLA	
	ON	OFF	ON	OFF	ON	OFF	ON	OFF
V <sub>L</sub>	495.3	495.5	497.2	495.8	496.1	497.3	497.9	495.8
Abs. Chg.	-0.2		1.4		-1.2		2.1	
I <sub>L</sub>	170.6	188.6	143.1	162.4	115.4	131.2	69.9	93.2
% Chg.	-9.5%		-11.9%		-12.0%		-25.0%	
PF	0.998	0.996	1.000	0.991	0.997	0.968	0.915	0.836
% Chg.	0.20%		0.90%		2.90%		7.90%	
kW	84.3	93.1	71.1	79.8	57.1	63.1	31.8	38.6
% Chg.	-9.5%		-10.9%		-9.5%		-17.8%	
kVARS	-5.1	8.1	0.6	10.8	4.1	16.3	14.1	25.4
% Chg.	-163.0%		-94.5%		-74.8%		-44.5%	
kVA	84.5	93.5	71.0	80.5	57.2	65.2	34.8	46.2
% Chg.	-9.6%		-11.8%		-12.3%		-24.7%	
V <sub>THD</sub>	1.965	1.949	2.084	1.932	2.026	1.965	2.119	2.033
% Chg.	0.8%		7.9%		3.1%		4.2%	
I <sub>THD</sub>	1.938	2.844	2.372	3.310	2.884	4.206	3.990	4.911
% Chg.	-31.9%		-28.3%		-31.4%		-18.8%	

**Cutler-Hammer**

- 7.2 As shown in the Data Summary Table, the percentage change in demand; i.e.,  $I_L$  and kVA; is significantly more pronounced at the lower load levels. Over the load ranges of 50% to 100% RLA and USES on, load current  $I_L$  and kVA decreased an average of 14.6%, demand in kW decreased an average of 11.8%, and total current harmonic distortion  $I_{THD}$  decreased by an average of 27.6%. The effects of the USES Unit are more pronounced at the lower RLA values.

The power factor increased by an average of 11.9% with the USES Unit connected to the feeder, with measured values significantly above the rated 0.882 (at 100% RLA). This measured power factor infers that power factor correction has been added to this motor in the past, however, records of this installation were not available at the time of this writing. The USES Unit improves the power factor to 0.998 from the already improved value of 0.996.

- 7.3 Analysis of the Harmonic Mitigation of the USES resulted in a slight increase in  $V_{THD}$  of 0.8% at 100% RLA, which is insignificant. The current harmonic values  $I_{THD}$ , however, were reduced by 31.9% at the same load. Total harmonic distortion (THD) measurements taken by the PP1 are a function of the 60Hz. fundamental value of the waveform. Future measurements will more exactly describe these efforts.

## 8 CONCLUSION


The results of this test provide conclusive evidence that the USES Unit does reduce amperage demand and power demand of an inductive-type load. These results are more clearly seen at lower load levels. Also, the test results show that the USES is able to improve the displacement angle between the voltage and current of each phase of a three phase inductive load, which is directly related to improved power factor of the load. This again is more noticeable at lower load conditions. The other pronounced functions of harmonic distortion reduction and transient voltage suppression were not proven during this testing, however, this testing was not designed to show these features of the USES. Further testing will describe more completely the harmonic and transient mitigation properties of the USES Unit.

## PPI Specifications

<u>Parameter</u>	<u>Specifications</u>
Voltage measurements	4 fully differential channels 10-600Vrms Accuracy: ±1% reading ±0.05% full scale
Voltage transients	50-6000 Vpk 1 microsecond minimum duration Accuracy: ±10% reading ±1% full scale Requires TASKCard PQPlus
Current measurements	4 fully independent current channels 10 - 200% of full-scale current probe rating Accuracy: ±1% reading ±0.05% full scale (at fundamental, plus current probe accuracy)
Current transients	10-300% CT full scale except Chan D 2-200% CT full scale 1 microsecond minimum duration Accuracy: ±10% reading ±1% full scale plus probe Requires TASKCard PQPlus
Frequency	Fundamental range 30 - 450 Hz Accuracy ±0.2% of reading
Update rates	All parameters updated once per second (Harmonic-based parameters updated every 5 seconds)
Environment	41°F to 113°F +5°C to +45°C Humidity 10% - 90% non-condensing
Battery	2 hours operation 3 hours full recharge (continuous operation from battery eliminator)
PC Software package	DRAN-VIEW

**Cutler-Hammer**

Certifications	(CE certification for model PP1 E, UL listing for model PPI)
Latest released version	PQPlus V2.4 TASK8000 V2.3 Inrush VI.2 TaskCard Flicker VI.0



## **FEEDER DATA**

I.D.	<u>SIZE</u>
2	3 - #2 + 1 - #8 GRD, 1-1/4" C
4	4 - #1/0 + 1 - #6 GRD, 2" C
7	3 - #350 kcmil + 1 - #4 GRD, 3" C
11	2 Sets of 3 - #4/0 + 1 - 2/0 Bare Cu. GRD, 3" C
14	4 - #350 kcmil + 1 - #4 GRD, 3" C
15	2 Sets of 3 - #250 kcmil + 1 - #2 GRD, 2-1/2" C
16	4 - #2 + 1 - #8 GRD, 1-1/4" C

Note: I.D. numbers for feeders shown in diamonds on oneline diagram.

100% RLA - USES ON







100% RLA - USES OFF

DRAHNETZ PPI-30000 N-G 2A ALL CHANNELS SUMMARY REPORT 11-02-20 Apr-198-89  
f= 50.00hz (H )  
" "C" "B" "A"  
495.2 494.7 0.046  
166.8 171.0 0.000  
62.37k 64.78k 85.85k  
PF -0.998 0.999 -0.998  
VR -82.557k 84.855k 86.06k  
VAR -5.621k -3.584k -5.972k  
UCF 1.401 1.397 1.395  
ICF 1.446 1.443 1.419  
Vthd 1.965 1.889 1.852  
Ithd 1.938 1.956 2.059  
Utilf 2.945k 9.357k 7.364k  
Titif 6.121k 7.785k 7.609k  
TDF 9.998 0.998 0.990  
DPF -8.998 -1.000 -0.998  
PH\_U 858.5 858.3 857.2  
PRESENT DEMAND: 253.0kw  
ACCUW ENERGY: 769.7kwHR


DRAHNETZ PPI-30000 N-G 2A ALL CHANNELS SUMMARY REPORT 11-22-10 Apr-06-99  
f= 59.95hz (H )  
" "C" "B" "A"  
495.2 494.7 0.044  
166.8 171.0 0.000  
62.37k 64.78k 85.85k  
PF 0.997 0.995 0.997  
VR 7.259k 9.13k 9.259k  
VAR 1.397 1.398 1.397  
UCF 1.453 1.442 1.429  
Vthd 1.949 1.969 1.959  
Ithd 1.644 2.771 2.763  
Utilf 3.755k 4.890k 6.34k  
Titif 3.171k 3.141k 3.358k  
TDF 0.398 0.998 0.998  
DPF 0.998 0.995 0.998  
PH\_U 859.0 858.9 857.6  
PRESENT DEMAND: 279.3kw  
ACCUW ENERGY: 856.2kwHR

100% RLA - USES ON


100% RLA - USES OFF



## 100% RLA - USES ON



## 100% RLA - USES OFF



## 100% RLA - USES ON

## 100% RLA - USES OFF

DRANET2 PPL-8000 N-G 2A		REF	495.6 U.	49.0 Hz	Apr-08-99 11:04:25
/FUND	HARMONICS:CH R		H#	MAGX	PHS
H#	HARM	Utd	1.993	%	
02	0.022	2312	19	0.118	214
03	0.148	0.043	206	0.006	346
04	0.062	174	201	0.011	36
05	1.022	3523	201	0.006	36
06	0.645	3524	200	0.006	36
07	0.032	3533	200	0.006	36
08	0.054	3534	200	0.006	36
09	0.011	104	193	0.006	36
10	0.011	162	193	0.006	36
11	0.032	265	193	0.006	36
12	0.011	167	209	0.006	36
13	0.065	124	209	0.006	36
14	0.011	653	209	0.006	36
15	0.043	106	209	0.006	36
16	0.009	67	209	0.006	36
17	0.215	194	34	0.006	35
18	0.010	244	34	0.006	35

DRANET2 PPL-8000 N-G 2B		REF	497.2 U.	49.0 Hz	Apr-08-99 11:04:30
/FUND	HARMONICS:CH B		H#	MAGX	PHS
H#	HARM	Utd	1.913	%	
02	0.021	252	0.192	0.006	36
03	0.188	213	0.006	215	0.006
04	0.053	0.002	38	0.006	36
05	1.123	220	39	0.006	36
06	0.021	264	40	0.006	36
07	0.571	210	41	0.006	36
08	0.032	338	41	0.006	36
09	0.096	258	43	0.006	36
10	0.021	118	43	0.006	36
11	0.021	611	43	0.006	36
12	0.009	226	43	0.006	36
13	0.075	1356	43	0.006	36
14	0.011	443	31	0.006	36
15	0.075	896	32	0.006	36
16	0.011	234	32	0.006	36
17	0.149	202	34	0.006	36
18	0.009	206	34	0.006	35

DRANET2 PPL-8000 N-G 2C		REF	495.5 U.	49.0 Hz	Apr-08-99 11:04:35
/FUND	HARMONICS:CH C		H#	MAGX	PHS
H#	HARM	Utd	1.931	%	
02	0.032	254	0.108	0.006	36
03	0.097	220	0.011	277	0.006
04	0.043	221	185	0.006	36
05	1.022	222	125	0.006	36
06	0.022	0.593	213	0.006	36
07	0.032	224	213	0.006	36
08	0.032	225	127	0.006	36
09	0.043	143	43	0.006	36
10	0.011	271	44	0.006	36
11	0.011	308	45	0.006	36
12	0.008	289	45	0.006	36
13	0.075	307	45	0.006	36
14	0.011	297	49	0.006	36
15	0.075	296	49	0.006	36
16	0.011	292	50	0.006	36
17	0.149	204	50	0.006	36
18	0.009	206	50	0.006	35

DRANET2 PPL-8000 N-G 2H		REF	495.6 U.	60.0 Hz	Apr-08-99 11:04:25
/FUND	HARMONICS:CH H		H#	MAGX	PHS
H#	HARM	Utd	1.993	%	
02	0.022	238	19	0.118	346
03	0.008	206	206	0.006	36
04	0.043	0.011	267	0.006	36
05	1.022	222	175	0.006	36
06	0.022	224	175	0.006	36
07	0.011	0.011	226	0.006	36
08	0.008	226	175	0.006	36
09	0.043	143	43	0.006	36
10	0.011	271	44	0.006	36
11	0.011	308	45	0.006	36
12	0.008	289	45	0.006	36
13	0.075	296	49	0.006	36
14	0.011	292	50	0.006	36
15	0.075	292	50	0.006	36
16	0.011	292	50	0.006	36
17	0.149	204	50	0.006	36
18	0.009	206	50	0.006	35

DRANET2 PPL-8000 N-G 2A		REF	495.6 U.	60.0 Hz	Apr-08-99 11:04:25
/FUND	HARMONICS:CH A		H#	MAGX	PHS
H#	HARM	Utd	1.993	%	
02	0.022	238	19	0.118	346
03	0.008	206	206	0.006	36
04	0.043	0.011	267	0.006	36
05	1.022	222	175	0.006	36
06	0.022	224	175	0.006	36
07	0.011	0.011	226	0.006	36
08	0.008	226	175	0.006	36
09	0.043	143	43	0.006	36
10	0.011	271	44	0.006	36
11	0.011	308	45	0.006	36
12	0.008	289	45	0.006	36
13	0.075	296	49	0.006	36
14	0.011	292	50	0.006	36
15	0.075	292	50	0.006	36
16	0.011	292	50	0.006	36
17	0.149	204	50	0.006	36
18	0.009	206	50	0.006	35

DRANET2 PPL-8000 N-G 2A		REF	495.6 U.	60.0 Hz	Apr-08-99 11:04:25
/FUND	HARMONICS:CH A		H#	MAGX	PHS
H#	HARM	Utd	1.917	%	
02	0.022	242	19	0.126	346
03	0.008	206	206	0.006	36
04	0.043	0.011	267	0.006	36
05	1.022	222	175	0.006	36
06	0.022	224	175	0.006	36
07	0.011	0.011	226	0.006	36
08	0.008	226	175	0.006	36
09	0.043	143	43	0.006	36
10	0.011	271	44	0.006	36
11	0.011	308	45	0.006	36
12	0.008	289	45	0.006	36
13	0.075	296	49	0.006	36
14	0.011	292	50	0.006	36
15	0.075	292	50	0.006	36
16	0.011	292	50	0.006	36
17	0.149	204	50	0.006	36
18	0.009	206	50	0.006	35

## 90% RLA - USES ON

## 90% RLA - USES OFF

DRANETZ PPI-8000 H-G 2A  
ALL CHANNELS SUMMARY REPORT 11-32-58 Apr-98-98  
f= 58.99hz (R )

	**A**	**B**	**C**	**D**	**EBC**
U	456.8	498.8	496.7	0.042	497.2
I	135.3	143.4	146.5	0.000	429.2
H	69.17k	71.36k	72.70k	0.000	213.2k
PF	0.999	0.999	0.999	0.000	1.000
UR	69.28k	71.44k	72.75k	0.000	213.2k
VRR	-2.537k	3.226k	-2.612k	0.000	-1.963k
UCF	1.401	1.392	1.396	2.546	
ICF	1.458	1.447	1.422	0.000	
Uthd	2.004	1.985	1.995	0.000	
Ithd	2.372	2.277	2.427	0.000	
Utif	6.148k	6.718k	6.182k	0.000	
Itif	9.767k	5.694k	5.452k	0.000	
TDF	0.998	0.998	0.999	1.000	
DPF	-1.880	-1.800	-1.000	0.000	
PH U	861.6	861.5	862.4	8	

PRESENT DEMAND: 813.2kW PROJ. DEMAND: 254.4kW  
ACCUM ENERGY: 988.6kWh PROJ. DEMAND: 266.5kW  
PRESENT DEMAND: 239.3kW PROJ. DEMAND: 858.1kW  
ACCUM ENERGY: 882.3kWh

DRANETZ PPI-8000 H-G 2A  
ALL CHANNELS SUMMARY REPORT 11-29-09 Apr-08-99  
f= 59.99hz (R )


	**A**	**B**	**C**	**D**	**EBC**
U	495.4	496.8	495.2	0.044	495.3
I	156.2	162.4	165.7	0.000	487.2
H	77.78k	80.16k	81.43k	0.000	239.3k
PF	0.992	0.998	0.993	0.000	0.991
UR	76.35k	81.10k	82.94k	0.000	241.5k
VRR	9.891k	12.79k	9.947k	0.000	32.60k
UCF	1.397	1.395	1.395	2.927	
ICF	1.449	1.434	1.421	0.000	
Uthd	1.932	1.858	1.844	0.000	
Ithd	2.310	2.237	2.224	0.000	
Utif	4.310k	5.031k	5.207k	0.000	
Itif	2.751k	2.658k	2.629k	0.000	
TDF	0.990	0.998	0.990	1.000	
DPF	0.990	0.998	0.993	0.000	
PH U	859.4	859.3	858.1	0	

PRESENT DEMAND: 239.3kW PROJ. DEMAND: 858.1kW  
ACCUM ENERGY: 882.3kWh


90% RLA - USES ON

11:33:31 Apr-08-99  
CORFINETZ PPI-0000 N-G 2R  
PHASOR: A


VOL. INGE: 497 ° 000.  
CURRENT: 140 ° 001.



ORANETT2 PP1-8000 N-G EH  
PHASOR: B




ORHNET2 PP1-6000 N-G 2A 11:34:00 Apr-08-99  
PHASOR: C VOLTAGE: 497° ± 240°  
CURRENT: 148° ± 241°




90% RLA - USES OFF

ORANETZ RP1-00000 N-G 2A  
 PHASOR: A  
 VOLTAGE:  
 495 V 000.  
 CURRENT:  
 0.000 A 000.  
 11:29:48 Apr-08-19



ORANETZ PPI-0000 N-G 2A 11:29:36 Apr-08-99



NETZ PPI-8000 N-G 2R

11:29 42 Apr-08-99


PHASOR: C

VOLTAGE:


496 ° 24.0

CURRENT:


164 ° 23.3



### 90% RLA - USES ON



### 90% RLA - USES OFF



## 75% RLA - USES ON

## 75% RLA - USES OFF

DRANETZ PPI-8000 N-G 2A  
ALL CHANNELS SUMMARY REPORT  
14:25:46 Apr-00-99  
f = 60.00hz (A )

==B== ==C== ==ABC=

U 495.6 495.8 496.1  
I 111.7 118.9 118.9  
H 55.27k 57.18k 58.84k  
PF 65.996 65.995 65.998  
VAR 55.38k 57.664k 58.95k  
UCF 1.401 1.396 1.394  
ICF 1.448 1.447 1.418  
Uthd 0.026 1.665 1.885  
Ithd 2.884 2.792 2.845  
Utif 7.235k 7.844k 5.980k  
Itif 5.808k 7.384k 6.415k  
TDF 0.997 0.996 0.997  
OPF 0.999 0.996 0.995  
PHU 0.659.6 0.659.8 0.658.5  
PRESENT DEMAND: 171.8kW  
ACUM ENERGY: 1.458MWHR




PROJ. DEMAND: 190.5kW  
ACUM ENERGY: 1.461MWHR

DRANETZ PPI-8000 N-G 2A  
ALL CHANNELS SUMMARY REPORT  
14:33:39 Apr-00-99  
f = 59.99hz (A )




==B== ==C== ==ABC=

U 496.5 496.6 496.8  
I 126.3 132.0 135.2  
H 68.99k 63.09k 65.34k  
PF 8.972 8.959 8.973  
VAR 62.72k 65.79k 67.15k  
UCF 14.65k 18.64k 15.49k  
ICF 1.398 1.396 1.394  
Uthd 1.965 1.825 1.853  
Ithd 4.206 3.934 3.941  
Utif 4.115k 4.102k 3.906k  
Itif 2.696k 1.956k 2.115k  
TDF 0.997 0.997 0.997  
OPF 0.974 0.968 0.974  
PHU 0.613 0.621 0.620  
PRESENT DEMAND: 189.4kW  
ACUM ENERGY: 1.461MWHR




75% RLA - USES ON







75% RLA - USES OFF



75% RLA - USES ON



75% RLA - USES OFF



## 75% RLA - USES ON

## 75% RLA - USES OFF

DRNETZ PPI-8000 N-G 2A HARMONICS:CH A				Apr-06-99 14:29:22			
FUND	ITnd	H#	REF	FUND	ITnd	H#	REF
MAGX	PH5	HAGX	PH5	HAGX	PH5	HAGX	PH5
02	1-165	229	19	02	1-165	229	19
03	1-866	250	20	03	1-866	250	20
04	1-879	251	21	04	1-879	251	21
05	1-933	252	22	05	1-933	252	22
06	1-714	253	23	06	1-714	253	23
07	1-717	254	24	07	1-717	254	24
08	1-903	255	25	08	1-903	255	25
09	1-933	256	26	09	1-933	256	26
10	1-935	257	27	10	1-935	257	27
11	1-936	258	28	11	1-936	258	28
12	1-936	259	29	12	1-936	259	29
13	1-936	260	30	13	1-936	260	30
14	1-936	261	31	14	1-936	261	31
15	1-936	262	32	15	1-936	262	32
16	1-936	263	33	16	1-936	263	33
17	1-936	264	34	17	1-936	264	34
18	1-936	265	35	18	1-936	265	35

DRNETZ PPI-8000 N-G 2A HARMONICS:CH B				Apr-06-99 14:29:27			
FUND	ITnd	H#	REF	FUND	ITnd	H#	REF
MAGX	PH5	HAGX	PH5	HAGX	PH5	HAGX	PH5
02	1-252	192	19	02	1-252	192	19
03	1-594	349	20	03	1-594	349	20
04	1-863	346	21	04	1-863	346	21
05	1-733	165	22	05	1-733	165	22
06	1-735	148	23	06	1-735	148	23
07	1-735	148	24	07	1-735	148	24
08	1-935	203	25	08	1-935	203	25
09	1-935	203	26	09	1-935	203	26
10	1-935	215	27	10	1-935	215	27
11	1-935	215	28	11	1-935	215	28
12	1-935	215	29	12	1-935	215	29
13	1-935	215	30	13	1-935	215	30
14	1-935	215	31	14	1-935	215	31
15	1-935	215	32	15	1-935	215	32
16	1-935	215	33	16	1-935	215	33
17	1-935	215	34	17	1-935	215	34
18	1-935	215	35	18	1-935	215	35

DRNETZ PPI-8000 N-G 2A HARMONICS:CH C				Apr-06-99 14:35:41			
FUND	ITnd	H#	REF	FUND	ITnd	H#	REF
MAGX	PH5	HAGX	PH5	HAGX	PH5	HAGX	PH5
02	1-165	229	19	02	1-165	229	19
03	1-866	250	20	03	1-866	250	20
04	1-879	251	21	04	1-879	251	21
05	1-933	252	22	05	1-933	252	22
06	1-714	253	23	06	1-714	253	23
07	1-717	254	24	07	1-717	254	24
08	1-903	255	25	08	1-903	255	25
09	1-933	256	26	09	1-933	256	26
10	1-935	257	27	10	1-935	257	27
11	1-936	258	28	11	1-936	258	28
12	1-936	259	29	12	1-936	259	29
13	1-936	260	30	13	1-936	260	30
14	1-936	261	31	14	1-936	261	31
15	1-936	262	32	15	1-936	262	32
16	1-936	263	33	16	1-936	263	33
17	1-936	264	34	17	1-936	264	34
18	1-936	265	35	18	1-936	265	35

DRNETZ PPI-8000 N-G 2A HARMONICS:CH D				Apr-06-99 14:35:47			
FUND	ITnd	H#	REF	FUND	ITnd	H#	REF
MAGX	PH5	HAGX	PH5	HAGX	PH5	HAGX	PH5
02	1-252	192	19	02	1-252	192	19
03	1-594	349	20	03	1-594	349	20
04	1-863	346	21	04	1-863	346	21
05	1-733	165	22	05	1-733	165	22
06	1-735	148	23	06	1-735	148	23
07	1-735	148	24	07	1-735	148	24
08	1-935	203	25	08	1-935	203	25
09	1-935	203	26	09	1-935	203	26
10	1-935	203	27	10	1-935	203	27
11	1-935	203	28	11	1-935	203	28
12	1-935	203	29	12	1-935	203	29
13	1-935	203	30	13	1-935	203	30
14	1-935	203	31	14	1-935	203	31
15	1-935	203	32	15	1-935	203	32
16	1-935	203	33	16	1-935	203	33
17	1-935	203	34	17	1-935	203	34
18	1-935	203	35	18	1-935	203	35

DRNETZ PPI-8000 N-G 2A HARMONICS:CH E				Apr-06-99 14:35:52			
FUND	ITnd	H#	REF	FUND	ITnd	H#	REF
MAGX	PH5	HAGX	PH5	HAGX	PH5	HAGX	PH5
02	1-165	229	19	02	1-165	229	19
03	1-866	250	20	03	1-866	250	20
04	1-879	251	21	04	1-879	251	21
05	1-933	252	22	05	1-933	252	22
06	1-714	253	23	06	1-714	253	23
07	1-717	254	24	07	1-717	254	24
08	1-903	255	25	08	1-903	255	25
09	1-933	256	26	09	1-933	256	26
10	1-935	257	27	10	1-935	257	27
11	1-936	258	28	11	1-936	258	28
12	1-936	259	29	12	1-936	259	29
13	1-936	260	30	13	1-936	260	30
14	1-936	261	31	14	1-936	261	31
15	1-936	262	32	15	1-936	262	32
16	1-936	263	33	16	1-936	263	33
17	1-936	264	34	17	1-936	264	34
18	1-936	265	35	18	1-936	265	35

## 50% RLA - USES ON

DRANET2 PP1-8000 N-G 2A  
ALL CHANNELS SUMMARY REPORT 13:30:19 Apr-98-99  
f = 59.99hz (A )

	**C**	**D**	**E**	**F**	**G**	**H**	**I**	**J**	**K**	**L**	**M**	**N**	**O**	**P**	**Q**	**R**	**S**	**T**	**U**	**V**	**W**	**X**	**Y**	**Z**	
A	497.0	497.3	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	497.9	
B	54.95	72.16	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	72.34	
C	29.65k	31.99k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	33.84k	
D	PF	0.918	0.889	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	0.934	
E	VAR	32.38k	25.98k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	36.22k	
F	UCF	12.79k	16.48k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k	12.91k		
G	ICF	1.402	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398	1.398		
H	Uthd	8.119	1.967	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	1.954	
I	Uthd	3.938	3.279	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	3.713	
J	Utif	5.188k	5.628k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	5.178k	
K	Titif	4.989k	5.561k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	5.524k	
L	TDF	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	0.394	
M	OPF	0.917	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	0.887	
N	PH U	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0	863.0		
O	PRESENT DEMAND:	95.49kW	PROJ. DEMAND:	143.3kW																					
P	ACCU ENERGY:	1.342mwhr																							

## 50% RLA - USES OFF

DRANET2 PP1-8000 N-G 2A  
ALL CHANNELS SUMMARY REPORT 13:24:49 Apr-08-99  
f = 59.99hz (A )

	**C**	**D**	**E**	**F**	**G**	**H**	**I**	**J**	**K**	**L**	**M**	**N**	**O**	**P**	**Q**	**R**	**S**	**T**	**U**	**V**	**W**	**X**	**Y**	**Z**	
A	495.3	495.4	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7	496.7		
B	86.89	95.02	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033	0.033		
C	36.70k	38.86k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k	40.31k		
D	PF	0.834	0.817	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855	0.855		
E	VAR	44.03k	47.58k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k	47.87k		
F	UCF	24.32k	27.45k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k	24.31k		
G	ICF	1.398	1.397	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394	1.394		
H	Uthd	2.033	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996	1.996		
I	Uthd	4.911	4.294	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449	4.449		
J	Utif	5.207k	4.342k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k	5.116k		
K	Titif	2.343k	2.168k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k	2.098k		
L	TDF	0.996	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997	0.997		
M	OPF	0.834	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818	0.818		
N	PH U	859.1	859.1	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6	856.6		
O	PRESENT DEMAND:	115.9kw	PROJ. DEMAND:	143.3kw																					
P	ACCU ENERGY:	1.331mwhr																							

50% RLA - USES ON







DRNET12 PPI-6000 H-G 29		Apr-08-99 13:31:56	
HARMONICS:CH A		S U. 60 MHz	
H#	FUND	REF	497
0.021	HARZ	H#	HARZ
0.158	227	0.897	PHS
0.217	234	0.898	36
0.375	242	0.898	37
0.625	245	0.898	38
0.875	246	0.898	39
1.125	247	0.898	40
1.375	248	0.898	41
1.625	249	0.898	42
1.875	250	0.898	43
2.125	251	0.898	44
2.375	252	0.898	45
2.625	253	0.898	46
2.875	254	0.898	47
3.125	255	0.898	48
3.375	256	0.898	49
3.625	257	0.898	50
3.875	258	0.898	51
4.125	259	0.898	52
4.375	260	0.898	53
4.625	261	0.898	54
4.875	262	0.898	55
5.125	263	0.898	56
5.375	264	0.898	57
5.625	265	0.898	58
5.875	266	0.898	59
6.125	267	0.898	60
6.375	268	0.898	61
6.625	269	0.898	62
6.875	270	0.898	63
7.125	271	0.898	64
7.375	272	0.898	65
7.625	273	0.898	66
7.875	274	0.898	67
8.125	275	0.898	68
8.375	276	0.898	69
8.625	277	0.898	70
8.875	278	0.898	71
9.125	279	0.898	72
9.375	280	0.898	73
9.625	281	0.898	74
9.875	282	0.898	75
10.125	283	0.898	76
10.375	284	0.898	77
10.625	285	0.898	78
10.875	286	0.898	79
11.125	287	0.898	80
11.375	288	0.898	81
11.625	289	0.898	82
11.875	290	0.898	83
12.125	291	0.898	84
12.375	292	0.898	85
12.625	293	0.898	86
12.875	294	0.898	87
13.125	295	0.898	88
13.375	296	0.898	89
13.625	297	0.898	90
13.875	298	0.898	91
14.125	299	0.898	92
14.375	300	0.898	93
14.625	301	0.898	94
14.875	302	0.898	95
15.125	303	0.898	96
15.375	304	0.898	97
15.625	305	0.898	98
15.875	306	0.898	99
16.125	307	0.898	100

50% BI & BUSINESS SEE



DRANET2	PP1-B0000	N-G	2R			Apr-98-99	13-26-17
X-FUND	HARMONICS	:CH	C	REF	496.	I_U.	0.0Hz
X-FUND	UTHD	L.	890	X			
H#	HAGX						
244	0.043						
099	0.000						
094	0.032						
124	0.000						
072	0.000						
003	0.000						
324	0.000						
023	0.000						
024	0.000						
025	0.000						
067	0.000						
068	0.000						
083	0.000						
04	0.000						
05	0.000						
07	0.000						
08	0.000						
09	0.000						
10	0.000						
11	0.000						
12	0.000						
13	0.000						
14	0.000						
15	0.000						
16	0.000						
17	0.000						
18	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
342	0.000						
410	0.000						
413	0.000						
445	0.000						
455	0.000						
472	0.000						
478	0.000						
55	0.000						
56	0.000						
PHS	HAGX						
326	0.000						
325	0.000						
328	0.000						
330	0.000						
340	0.000						
34							

50% RLA - USES ON




50% RLA - USES OFF



### 50% RLA - USES ON



### 50% RLA - USES OFF



## 50% RLA - USES ON

## 50% RLA - USES OFF

DRAINETZ PPI-8000 N-G 2A		Apr-98-99 13:32:02	
HARMONICS:CH A		Uthd 457.5 U. 60.0Hz	
H#	MAGX	PHS	H# MAGX
0.021	0.027	0.025	0.024
0.022	0.024	0.023	0.023
0.023	0.021	0.020	0.020
0.024	0.021	0.019	0.019
0.025	0.021	0.018	0.018
0.026	0.021	0.017	0.017
0.027	0.021	0.016	0.016
0.028	0.021	0.015	0.015
0.029	0.021	0.014	0.014
0.030	0.021	0.013	0.013
0.031	0.021	0.012	0.012
0.032	0.021	0.011	0.011
0.033	0.021	0.010	0.010
0.034	0.021	0.009	0.009
0.035	0.021	0.008	0.008
0.036	0.021	0.007	0.007
0.037	0.021	0.006	0.006
0.038	0.021	0.005	0.005
0.039	0.021	0.004	0.004
0.040	0.021	0.003	0.003
0.041	0.021	0.002	0.002
0.042	0.021	0.001	0.001
0.043	0.021	0.000	0.000
0.044	0.021	-0.001	-0.001
0.045	0.021	-0.002	-0.002
0.046	0.021	-0.003	-0.003
0.047	0.021	-0.004	-0.004
0.048	0.021	-0.005	-0.005
0.049	0.021	-0.006	-0.006
0.050	0.021	-0.007	-0.007
0.051	0.021	-0.008	-0.008
0.052	0.021	-0.009	-0.009
0.053	0.021	-0.010	-0.010
0.054	0.021	-0.011	-0.011
0.055	0.021	-0.012	-0.012
0.056	0.021	-0.013	-0.013
0.057	0.021	-0.014	-0.014
0.058	0.021	-0.015	-0.015
0.059	0.021	-0.016	-0.016
0.060	0.021	-0.017	-0.017
0.061	0.021	-0.018	-0.018
0.062	0.021	-0.019	-0.019
0.063	0.021	-0.020	-0.020
0.064	0.021	-0.021	-0.021
0.065	0.021	-0.022	-0.022
0.066	0.021	-0.023	-0.023
0.067	0.021	-0.024	-0.024
0.068	0.021	-0.025	-0.025
0.069	0.021	-0.026	-0.026
0.070	0.021	-0.027	-0.027
0.071	0.021	-0.028	-0.028
0.072	0.021	-0.029	-0.029
0.073	0.021	-0.030	-0.030
0.074	0.021	-0.031	-0.031
0.075	0.021	-0.032	-0.032
0.076	0.021	-0.033	-0.033
0.077	0.021	-0.034	-0.034
0.078	0.021	-0.035	-0.035
0.079	0.021	-0.036	-0.036
0.080	0.021	-0.037	-0.037
0.081	0.021	-0.038	-0.038
0.082	0.021	-0.039	-0.039
0.083	0.021	-0.040	-0.040
0.084	0.021	-0.041	-0.041
0.085	0.021	-0.042	-0.042
0.086	0.021	-0.043	-0.043
0.087	0.021	-0.044	-0.044
0.088	0.021	-0.045	-0.045
0.089	0.021	-0.046	-0.046
0.090	0.021	-0.047	-0.047
0.091	0.021	-0.048	-0.048
0.092	0.021	-0.049	-0.049
0.093	0.021	-0.050	-0.050
0.094	0.021	-0.051	-0.051
0.095	0.021	-0.052	-0.052
0.096	0.021	-0.053	-0.053
0.097	0.021	-0.054	-0.054
0.098	0.021	-0.055	-0.055
0.099	0.021	-0.056	-0.056
0.100	0.021	-0.057	-0.057
0.101	0.021	-0.058	-0.058
0.102	0.021	-0.059	-0.059
0.103	0.021	-0.060	-0.060
0.104	0.021	-0.061	-0.061
0.105	0.021	-0.062	-0.062
0.106	0.021	-0.063	-0.063
0.107	0.021	-0.064	-0.064
0.108	0.021	-0.065	-0.065
0.109	0.021	-0.066	-0.066
0.110	0.021	-0.067	-0.067
0.111	0.021	-0.068	-0.068
0.112	0.021	-0.069	-0.069
0.113	0.021	-0.070	-0.070
0.114	0.021	-0.071	-0.071
0.115	0.021	-0.072	-0.072
0.116	0.021	-0.073	-0.073
0.117	0.021	-0.074	-0.074
0.118	0.021	-0.075	-0.075
0.119	0.021	-0.076	-0.076
0.120	0.021	-0.077	-0.077
0.121	0.021	-0.078	-0.078
0.122	0.021	-0.079	-0.079
0.123	0.021	-0.080	-0.080
0.124	0.021	-0.081	-0.081
0.125	0.021	-0.082	-0.082
0.126	0.021	-0.083	-0.083
0.127	0.021	-0.084	-0.084
0.128	0.021	-0.085	-0.085
0.129	0.021	-0.086	-0.086
0.130	0.021	-0.087	-0.087
0.131	0.021	-0.088	-0.088
0.132	0.021	-0.089	-0.089
0.133	0.021	-0.090	-0.090
0.134	0.021	-0.091	-0.091
0.135	0.021	-0.092	-0.092
0.136	0.021	-0.093	-0.093
0.137	0.021	-0.094	-0.094
0.138	0.021	-0.095	-0.095
0.139	0.021	-0.096	-0.096
0.140	0.021	-0.097	-0.097
0.141	0.021	-0.098	-0.098
0.142	0.021	-0.099	-0.099
0.143	0.021	-0.100	-0.100
0.144	0.021	-0.101	-0.101
0.145	0.021	-0.102	-0.102
0.146	0.021	-0.103	-0.103
0.147	0.021	-0.104	-0.104
0.148	0.021	-0.105	-0.105
0.149	0.021	-0.106	-0.106
0.150	0.021	-0.107	-0.107
0.151	0.021	-0.108	-0.108
0.152	0.021	-0.109	-0.109
0.153	0.021	-0.110	-0.110
0.154	0.021	-0.111	-0.111
0.155	0.021	-0.112	-0.112
0.156	0.021	-0.113	-0.113
0.157	0.021	-0.114	-0.114
0.158	0.021	-0.115	-0.115
0.159	0.021	-0.116	-0.116
0.160	0.021	-0.117	-0.117
0.161	0.021	-0.118	-0.118
0.162	0.021	-0.119	-0.119
0.163	0.021	-0.120	-0.120
0.164	0.021	-0.121	-0.121
0.165	0.021	-0.122	-0.122
0.166	0.021	-0.123	-0.123
0.167	0.021	-0.124	-0.124
0.168	0.021	-0.125	-0.125
0.169	0.021	-0.126	-0.126
0.170	0.021	-0.127	-0.127
0.171	0.021	-0.128	-0.128
0.172	0.021	-0.129	-0.129
0.173	0.021	-0.130	-0.130
0.174	0.021	-0.131	-0.131
0.175	0.021	-0.132	-0.132
0.176	0.021	-0.133	-0.133
0.177	0.021	-0.134	-0.134
0.178	0.021	-0.135	-0.135
0.179	0.021	-0.136	-0.136
0.180	0.021	-0.137	-0.137
0.181	0.021	-0.138	-0.138
0.182	0.021	-0.139	-0.139
0.183	0.021	-0.140	-0.140
0.184	0.021	-0.141	-0.141
0.185	0.021	-0.142	-0.142
0.186	0.021	-0.143	-0.143
0.187	0.021	-0.144	-0.144
0.188	0.021	-0.145	-0.145
0.189	0.021	-0.146	-0.146
0.190	0.021	-0.147	-0.147
0.191	0.021	-0.148	-0.148
0.192	0.021	-0.149	-0.149
0.193	0.021	-0.150	-0.150
0.194	0.021	-0.151	-0.151
0.195	0.021	-0.152	-0.152
0.196	0.021	-0.153	-0.153
0.197	0.021	-0.154	-0.154
0.198	0.021	-0.155	-0.155
0.199	0.021	-0.156	-0.156
0.200	0.021	-0.157	-0.157
0.201	0.021	-0.158	-0.158
0.202	0.021	-0.159	-0.159
0.203	0.021	-0.160	-0.160
0.204	0.021	-0.161	-0.161
0.205	0.021	-0.162	-0.162
0.206	0.021	-0.163	-0.163
0.207	0.021	-0.164	-0.164
0.208	0.021	-0.165	-0.165
0.209	0.021	-0.166	-0.166
0.210	0.021	-0.167	-0.167
0.211	0.021	-0.168	-0.168
0.212	0.021	-0.169	-0.169
0.213	0.021	-0.170	-0.170
0.214	0.021	-0.171	-0.171
0.215	0.021	-0.172	-0.172
0.216	0.021	-0.173	-0.173
0.217	0.021	-0.174	-0.174
0.218	0.021	-0.175	-0.175
0.219	0.021	-0.176	-0.176
0.220	0.021	-0.177	-0.177
0.221	0.021	-0.178	-0.178
0.222	0.021	-0.179	-0.179
0.223	0.021	-0.180	-0.180
0.224	0.021	-0.181	-0.181
0.225	0.021	-0.182	-0.182
0.226	0.021	-0.183	-0.183
0.227	0.021	-0.184	-0.184
0.228	0.021	-0.185	-0.185
0.229	0.021	-0.186	-0.186
0.230	0.021	-0.187	-0.187
0.231	0.021	-0.188	-0.188
0.232	0.021	-0.189	-0.189
0.233	0.021	-0.190	-0.190
0.234	0.021	-0.191	-0.191
0.235	0.021	-0.192	-0.192
0.236	0.021	-0.193	-0.193
0.237	0.021	-0.194	-0.194
0.238	0.021	-0.195	-0.195
0.239	0.021	-0.196	-0.196
0.240	0.021	-0.197	-0.197
0.241	0.021	-0.198	-0.198
0.242	0.021	-0.199	-0.199
0.243	0.021	-0.200	-0.200
0.244	0.021	-0.201	-0.201
0.245	0.021	-0.202	-0.202
0.246	0.021	-0.203	-0.203
0.247	0.021	-0.204	-0.204
0.248	0.021	-0.205	-0.205
0.249	0.021	-0.206	-0.206
0.250	0.021	-0.207	-0.207
0.251	0.021	-0.208	-0.208
0.252	0.021	-0.209	-0.209
0.253	0.021	-0.210	-0.210
0.254	0.021	-0.211	-0.211
0.255	0.021	-0.212	-0.212
0.256	0.021	-0.213	-0.213
0.257	0.021	-0.214	-0.214
0.258	0.021	-0.215	-0.215
0.259	0.021	-0.216	-0.216
0.260	0.021	-0.217	-0.217
0.261	0.021	-0.218	-0.218
0.262	0.021	-0.219	-0.219
0.263	0.021	-0.220	-0.220
0.264	0.021	-0.221	-0.221
0.265	0.021	-0.222	-0.222
0.266	0.021	-0.223	

## 50% RLA - USES ON

DRAINETZ PPI-8000 N-G 2A  
ALL CHANNELS SUMMARY REPORT 13:51:59 Apr-08-99  
F= 59.99hz (A )




	"0"	"C"	"D"	"ABC"	
U	497.9	499.5	497.6	498.3	
I	66.49	73.99	74.32	70.99	
W	38.69k	33.20k	34.83k	38.63k	
PF	0.924	0.858	0.942	0.922	
VA	33.10k	36.96k	36.98k	36.90k	
VAR	12.63k	16.23k	12.44k	11.38k	
UCF	1.481	1.397	1.397	1.538	
ICF	1.376	1.412	1.394	1.099	
Uthd	2.695	1.987	2.002	0.699	
Itbd	3.935	3.228	3.669	0.999	
Utrf	5.308k	5.877k	5.511k	6.866k	
Itrf	5.352k	5.552k	5.640k	6.866k	
TDF	0.993	0.995	0.994	1.000	
DPF	0.923	0.898	0.942	0.800	
PH U	863.6	863.3	862.0	862.0	
PRESENT DEMAND:	98.63kW	PROJ. DEMAND:	115.2kW	PROJ. DEMAND:	116.4kW
ACCU M ENERGY:	1.380MWHR	ACCU M ENERGY:	1.384MWHR	ACCU M ENERGY:	1.364MWHR

## 50% RLA - USES OFF




DRAINETZ PPI-8000 N-G 2R  
ALL CHANNELS SUMMARY REPORT 13:43:56 Apr-08-99  
F= 60.01hz (A )

	"E"	"C"	"D"	"ABC"	
U	496.9	496.5	496.8	496.3	
I	89.75	90.02	96.62	82.33	
W	37.18k	39.98k	41.99k	31.84k	
PF	0.834	0.816	0.866	0.838	
VA	44.68k	48.87k	47.98k	34.14k	
VAR	24.63k	28.22k	24.93k	27.19k	
UCF	1.398	1.396	1.395	1.477	
ICF	1.374	1.411	1.427	0.893	
Uthd	1.995	1.892	1.927	0.908	
Itbd	4.824	4.289	4.464	2.000	
Utrf	5.795k	5.438k	5.679k	2.000	
Itrf	2.303k	2.168k	2.069k	0.992	
TDF	0.996	0.997	0.997	1.000	
DPF	0.834	0.818	0.862	0.882	
PH U	862.5	862.2	862.0	860.9	
PRESENT DEMAND:	116.4kW	PROJ. DEMAND:	115.2kW	PROJ. DEMAND:	115.2kW
ACCU M ENERGY:	1.364MWHR	ACCU M ENERGY:	1.384MWHR	ACCU M ENERGY:	1.380MWHR

## 50% RLA - USES ON







## 50% RLA - USES OFF



**50% RLA - USES OFF**

**50% RLA - USES ON**



## 50% RLA - USES ON

DRAINETZ PPI-6000 H-G 2H		REF 497.0 U. 60.0Hz		Apr-08-99 13:53:48	
HARMONICS:CH A		HARMONICS:CH B		HARMONICS:CH C	
xFUND	Uthd	xFUND	Uthd	xFUND	Uthd
H#	MAGX	H#	MAGX	H#	MAGX
02	0.011	215	0.029	169	0.056
03	0.019	323	0.021	202	0.060
04	0.004	879	0.001	200	0.043
05	0.021	221	0.023	200	0.058
07	0.004	358	0.001	168	0.088
08	0.011	199	0.011	202	0.088
09	0.011	355	0.011	201	0.088
10	0.011	355	0.011	201	0.088
11	0.011	355	0.011	201	0.088
12	0.011	286	0.011	201	0.088
13	0.011	286	0.011	201	0.088
14	0.011	286	0.011	201	0.088
15	0.011	286	0.011	201	0.088
16	0.011	286	0.011	201	0.088
17	0.011	286	0.011	201	0.088
18	0.011	255	0.011	201	0.088

DRAINETZ PPI-6000 H-G 2H		REF 499.0 U. 60.0Hz		Apr-08-99 13:53:48	
HARMONICS:CH A		HARMONICS:CH B		HARMONICS:CH C	
xFUND	Uthd	xFUND	Uthd	xFUND	Uthd
H#	MAGX	H#	MAGX	H#	MAGX
03	0.011	240	0.002	169	0.056
04	0.004	200	0.001	200	0.043
05	0.021	200	0.021	200	0.058
07	0.004	169	0.001	200	0.088
08	0.011	200	0.011	200	0.088
09	0.011	200	0.011	200	0.088
10	0.011	200	0.011	200	0.088
11	0.011	200	0.011	200	0.088
12	0.011	200	0.011	200	0.088
13	0.011	200	0.011	200	0.088
14	0.011	200	0.011	200	0.088
15	0.011	200	0.011	200	0.088
16	0.011	200	0.011	200	0.088
17	0.011	200	0.011	200	0.088
18	0.011	200	0.011	200	0.088

DRAINETZ PPI-6000 H-G 2H		REF 497.0 U. 60.0Hz		Apr-08-99 13:46:07	
HARMONICS:CH A		HARMONICS:CH B		HARMONICS:CH C	
xFUND	Uthd	xFUND	Uthd	xFUND	Uthd
H#	MAGX	H#	MAGX	H#	MAGX
02	0.011	215	0.029	169	0.056
03	0.019	323	0.021	202	0.060
04	0.004	879	0.001	200	0.043
05	0.021	221	0.023	200	0.058
07	0.004	358	0.001	168	0.088
08	0.011	199	0.011	202	0.088
09	0.011	355	0.011	201	0.088
10	0.011	355	0.011	201	0.088
11	0.011	355	0.011	201	0.088
12	0.011	355	0.011	201	0.088
13	0.011	355	0.011	201	0.088
14	0.011	355	0.011	201	0.088
15	0.011	355	0.011	201	0.088
16	0.011	355	0.011	201	0.088
17	0.011	355	0.011	201	0.088
18	0.011	355	0.011	201	0.088

DRAINETZ PPI-6000 H-G 2H		REF 498.0 U. 60.0Hz		Apr-08-99 13:46:12	
HARMONICS:CH A		HARMONICS:CH B		HARMONICS:CH C	
xFUND	Uthd	xFUND	Uthd	xFUND	Uthd
H#	MAGX	H#	MAGX	H#	MAGX
02	0.011	215	0.029	169	0.056
03	0.019	323	0.021	202	0.060
04	0.004	879	0.001	200	0.043
05	0.021	221	0.023	200	0.058
07	0.004	358	0.001	168	0.088
08	0.011	199	0.011	202	0.088
09	0.011	355	0.011	201	0.088
10	0.011	355	0.011	201	0.088
11	0.011	355	0.011	201	0.088
12	0.011	355	0.011	201	0.088
13	0.011	355	0.011	201	0.088
14	0.011	355	0.011	201	0.088
15	0.011	355	0.011	201	0.088
16	0.011	355	0.011	201	0.088
17	0.011	355	0.011	201	0.088
18	0.011	355	0.011	201	0.088

